



Lodging Establishment Inspection Report

Establishment Information	
Facility Name AMERICINN RIVERFRONT	Facility Type Lodging 100-199 (LH3)
Facility ID # ASTS-AAWQET	Facility Telephone # 608 769-0800
Facility Address 1835 ROSE ST LA CROSSE , WI 54603	
Licensee Name TROUTCREEK 1 LLC	Licensee Address 12554 STATE HWY 131 SOLDIERS GROVE , WI 54655

Inspection Information		
Inspection Type Routine	Inspection Date 10/20/2016	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
Total # 0

Comments
<p>Rooms inspected - laundry, 128, 105, 109, 136, 137, 240, 238, 237, 256. There was a missing screen in 109 that was installed during the inspection. there are several types of smoke detectors in use. Maintenance informed me that he is switching to the dual smoke/CO detectors. I could not determine if the detectors were functioning so maintenance was asked to check on rooms 109, 136, 137, and 237 and call me with an update. I recommend a log be started to note where the new ones have been installed.</p>

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

Doug Schaefer
(608) 785-9679