



Lodging Establishment Inspection Report

Establishment Information	
Facility Name HOLIDAY INN EXPRESS - ONALASKA	Facility Type Lodging 31-99 Rooms (LH2)
Facility ID # BSAW-87SRBP	Facility Telephone # 608 783-6555
Facility Address 9409 STATE ROAD 16 ONALASKA , WI 54650	
Licensee Name SELECT ONALASKA LLC	Licensee Address 9409 STATE ROAD 16 ONALASKA , WI 54650-8359

Inspection Information		
Inspection Type Routine	Inspection Date February 9, 2017	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
Total # 0

Comments
Contact Sam (785-9732) when corrected or with questions. Check and repair/replace emergency lights between rooms 214 & 212 and light #27 (did not light when tested).

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Tim Klinger

Sanitarian

Samuel Welch
(608) 785-9732