



Lodging Establishment Inspection Report

Establishment Information	
Facility Name BAYMONT INN & SUITES	Facility Type Lodging 31-99 Rooms (LH2)
Facility ID # BHEP-8CRNTG	Facility Telephone # 608 783-7191
Facility Address 3300 KINNEY COULEE RD N ONALASKA , WI 54650	
Licensee Name CRESCENT LODGING MANAGEMENT INC	Licensee Address 3300 N KINNEY COULEE RD ONALASKA , WI 54650

Inspection Information		
Inspection Type Routine	Inspection Date 02/19/2016	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 5 Room: 108</p> <p>Observed Violations - 48 - Screens REPEAT OBSERVATION: Window screen missing from room 108. CORRECTIVE ACTION(S): Provide screening in good repair on all windows that can be opened to the outside. Correct By: 26-Feb-2016 CODE CITATION: DHS 195.14 (2) (e) Window screens. All windows that can be opened in sleeping rooms shall be screened, using 16 mesh or finer material. If sleeping rooms are not effectively air-conditioned, doors opening to the outside shall be similarly screened. Room: Ice machine each floor (3)</p> <p>Observed Violations - 04 - XConnection REPEAT OBSERVATION: The following cross-connections have been identified: the drains from the ice bin and make unit on each of the 3 ice machines. CORRECTIVE ACTION(S): Provide an air gap between each drain line and the floor drain. Correct By: 26-Feb-2016 CODE CITATION: DHS 195.10 (4) PLUMBING. All plumbing and fixtures shall meet the requirements contained in ch. SPS 382 and shall be maintained in good repair and in a sanitary condition. Room: 106, various</p> <p>Observed Violations - 21 - 1 ___ Utensil Sanit. OBSERVATION: Multi-use food contact surfaces, such as coffee carafes are not being washed, rinsed and sanitized for different guests. CORRECTIVE ACTION(S): All multi-use utensils must be washed, rinsed and sanitized using approved methods, equipment and chemicals. Provide approved 3 compartment sink or approved commercial dish machine for this purpose. Test sanitizer strength in manual/mechanical methods. Provide means of testing hot water sanitization, if applicable. No utensils for food contact may be washed in a guestroom lavatory. Correct By: 19-Feb-2016 CODE CITATION: DHS 195.11 (3) (a) Whenever multi-use glasses, ice buckets or other utensils are provided for a guest, the items shall be washed, rinsed and sanitized in an approved manner before being provided for use by a different guest. Utensils, when furnished, shall be free of cracks or chips. The food-content surfaces shall be smooth, nontoxic, corrosion-resistant, nonabsorbent and easily accessible for cleaning. Room: Laundry room, water heater room, pool heater room</p> <p>Observed Violations - 46 - Smoke and Carbon Monoxide Detection</p>

OBSERVATION: Carbon monoxide detector absent where Fuel Burning Appliances are present in the mechanical room adjacent to the laundry and the pool heaters in the pool mechanical room.

CORRECTIVE ACTION(S): Provide carbon monoxide detectors in all required locations - see DHS 195 and included requirements. Correct By: 26-Feb-2016

CODE CITATION: DHS 195.145 (3) INSTALLATION REQUIREMENTS.

The operator shall install carbon monoxide detectors in compliance with the requirements of s. 101.149 (2), stats., and s. SPS 321.097 or 362.1200, as follows: (a) Except as provided in par. (b) or in sub. (6) of this section, the operator shall install a carbon monoxide detector in each residential building in all of the following places not later than the date specified under par. (c):

1. In the basement of the building if the basement has a fuel-burning appliance.
2. Within 15 feet of each sleeping area of a unit that has a fuel-burning appliance.
3. Within 15 feet of each sleeping area of a unit that is immediately adjacent to a unit, located on the same floor level that has a fuel-burning appliance.
4. In each room that has a fuel-burning appliance and that is not used as a sleeping area, not more than 75 ft from the fuel burning appliance.
5. In each hallway leading from a unit that has a fuel-burning appliance, in a location that is within 75 ft from the unit measure from the door of the unit along the hallway leading from the unit, except that, if there is no electrical outlet within this distance, the operator shall place the carbon monoxide detector at the closest available electrical outlet in the hallway.

(b) If a unit is not part of a multiunit building, the operator need not install more than one carbon monoxide detector in the unit.

(c) 1. Except as provided under subd. 2., the operator shall comply with the requirements of this subsection before a residential building is occupied.

2. The operator shall comply with the requirements of this subsection not later than April 1, 2010, if construction of the residential building was initiated before October 1, 2008, or if the department of commerce approved the plans for the construction of the building under s. 101.12, Stats., before October 1, 2008.

Room: 108, various

Observed Violations - 29 - Cleanl. of Equip. & Furn.

REPEAT OBSERVATION: The jetted tub in room 108 contained standing water and internal componenets of the jetted tubs are not cleaned and disinfected between uses.

CORRECTIVE ACTION(S): Maintain equipment and furnishings in a clean condition. Correct By: 19-Feb-2016

CODE CITATION: DHS 195.11 (6) All equipment and furnishings shall be kept clean, free from odor and in good repair.

Comments

[Contact Sam \(785-9732\) when corrected or with questions.](#)

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Salina Foster

Sanitarian



Samuel Welch
(608) 785-9732