

LA CROSSE COUNTY  
HEALTH DEPARTMENT  
Environmental Health Division



STATE OF WISCONSIN  
Bureau of Environmental and  
Occupational Health  
DHS 195, Wis. Admin. Code

### Lodging Establishment Inspection Report

<b>Establishment Information</b>	
Facility Name ECONOLOGDE	Facility Type Lodging 31-99 Rooms (LH2)
Facility ID # HSAT-7QXAGN	Facility Telephone # 608 781-0200
Facility Address 1906 ROSE ST LA CROSSE, WI 54603	
Licensee Name DRAGAN INC	Licensee Address 1112 PARKRIDGE DR ONALASKA, WI 54650

<b>Inspection Information</b>		
Inspection Type Routine	Inspection Date January 23, 2015	Total Time Spent

**OPERATOR** - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

<b>Observed Violations</b>
<p><b>Total # 3</b></p> <p>Room: 116, 120, 128  <b>Observed Violations - 46 - Smoke and Carbon Monoxide Detection</b>  <b>REPEAT OBSERVATION:</b> Smoke detectors are absent or not in working order in 116, 120, 128..  <b>CORRECTIVE ACTION(S):</b> Provide operational smoke detectors in all sleeping rooms and required locations. Correct By: 23-Jan-2015  <b>CODE CITATION:</b> DHS 195.14 (2) (c) Smoke detection. Each cabin or cottage shall be provided with at least one approved, listed and labeled smoke detector located in a manner consistent with the manufacturer's recommendations.</p> <p>Room: 205  <b>Observed Violations - 29 - Cleanl. of Equip. &amp; Furn.</b>  <b>OBSERVATION:</b> Box spring in room 205 is soiled on head of bed facing door.  <b>CORRECTIVE ACTION(S):</b> Maintain equipment and furnishings in a clean condition. Correct By: 30-Jan-2015  <b>CODE CITATION:</b> DHS 195.11 (6) All equipment and furnishings shall be kept clean, free from odor and in good repair.</p> <p>Room: 115, 122, 232  <b>Observed Violations - 50 - 1___ Clean Rooms</b></p>

**OBSERVATION:** Dust and debris noted behind tables in rooms 122, 232, 115.  
**CORRECTIVE ACTION(S):** Maintain all sleeping rooms in a clean and sanitary condition. Correct By: 30-Jan-2015 Correct By: 28-Jan-2015  
**CODE CITATION:** DHS 195.15 (2) ROOMS. The floors, walls and ceilings of all rooms shall be maintained in a clean and sanitary condition and in a good state of repair.

**Comments**

1. Rooms inspected 105, 109, 115, 116, 120, 122, 128, 232, 221, 205, 201.
2. Repair screen in room 221 - small tear on bottom right corner.
3. General cleaning needed in all rooms behind dressers and behind beds - small accumulations of dirt/dust noted behind them. Clean more frequently.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Sanitarian



**Nicole Frankfourth**  
(608) 785-9731