



Recreational Educational Camp Establishment Inspection Report

<b>Establishment Information</b>	
Facility Name CAMP EHAWEE	Facility Type Recreational/Educational Camp (RRE)
Facility ID # BSAW-86PHAA	Facility Telephone # 608
Facility Address N9559 WILD RD MINDORO , WI 54644	
Licensee Name GIRL SCOUTS OF WISCONSIN- BADGERLAND INC	Licensee Address 2710 SKI LN MADISON , WI 53713

<b>Inspection Information</b>		
Inspection Type Routine	Inspection Date 07/28/2016	Total Time Spent

<b>Equipment Temperatures</b>	
Description	Temperature (Fahrenheit)
Refrigeration	41

<b>Warewashing Info</b>						
Machine Name	Sanitization Method	Thermo Label	PPM	Sanitizer Name	Sanitizer Type	Temperature
Dish machine 4 C sink	high temperature chemical	pass 160 degrees		nsu	QA	

**OPERATOR** - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

**Observed Violations****Total # 5****Risk/Intervention - 08 - Adequate handwashing facilities supplied and accessible**

**REPEAT OBSERVATION:** No single-use toweling in dispenser or other hand drying device available at men's room handwashing sink for hand drying.

**CORRECTIVE ACTION(S):** Provide single-use toweling or other approved devices at handwashing sink to facilitate proper handwashing. Correct By: 28-Jul-2016

**CODE CITATION:** 6-301.12 Each HANDWASHING SINK or group of adjacent HANDWASHING SINKS shall be provided with:

(A) Individual, disposable towels; [Pf]

(B) A continuous towel system that supplies the user with a clean towel; Pf or

(C) A heated-air hand drying device; [Pf] or

(D) A hand drying device that employs an air-knife system that delivers high velocity, pressurized air at ambient temperatures. [Pf]

**Risk/Intervention - 08 - Adequate handwashing facilities supplied and accessible**

**REPEAT OBSERVATION:** No handwashing signage provided at men's room handwashing sink.

**CORRECTIVE ACTION(S):** Provide handwashing signage at all handwashing sinks used by food employees. Correct By: 28-Jul-2016

**CODE CITATION:** 6-301.14 A sign or poster that notifies FOOD EMPLOYEES to wash their hands shall be provided at all HANDWASHING SINKS used by FOOD EMPLOYEES and shall be clearly visible to FOOD EMPLOYEES.

**Observed Violations - 37R - Fire fighting equipment and fire safety requirements met**

**OBSERVATION:** Camp does not have smoke detectors and or carbon monoxide detectors properly installed in all permanent structures. Bertha Shuman missing smoke and CO detectors, Marinuka missing smoke and CO detectors, Stry missing smoke and CO detectors.

**CORRECTIVE ACTION(S):** Provide necessary fire safety equipment or materials to comply with SPS 361 to 365. Correct By: 29-Jul-2016

**CODE CITATION:** ATCP 78.18(4)(c)2. For permanent structures, a camp shall comply with the fire safety requirements of chs. SPS 314 and 361 to 365, including rules on isolation of fire hazards, fire escapes, fire exits, fire extinguishers, fire alarm systems, smoke detectors, exit lighting, space heaters, ventilation and directions of escape.

**Observed Violations - 57R - Medications labeled and kept locked**

**OBSERVATION:** Medications are not kept in a locked unit. Locking storage was available but not locked. Room was not locked.

**CORRECTIVE ACTION(S):** Provide an approved locked storage area to store all medications that are required to be surrendered to camp health service staff by campers and staff under 18 years of age. Correct By: 28-Jul-2016

**CODE CITATION:** ATCP 78.19(6)(b) Except as allowed in par. (c), all medication brought to camp by a camper or staff member under 18 years of age shall be kept in a locked unit and shall be administered by health services staff qualified under sub. (5) (b), except that bee sting medication, inhalers, an insulin syringe or other medication or device used in the event of life threatening situations may be carried by a camper or staff member. Each camper or staff member 18 years of age or older may take responsibility for the security of his or her personal medication.

**Observed Violations - 9R - Air gaps/approved backflow device on water supply outlets**

**OBSERVATION:** Hose bibs are not equipped with back flow preeventers throughout the camp. One noted on Bertha Shuman and one on the pool deck.

**CORRECTIVE ACTION(S):** Install hose bib backflow preventers. Correct By: 29-Aug-2016

**CODE CITATION:** ATCP 78.12 (3)(b) Air gaps or approved devices to prevent backflow shall be provided on all water supply outlets.

**Comments**

The camp was missing some smoke and carbon monoxide detectors. Many detectors were not checked due to location and activity at time of the inspection. Recommend documenting all facilities, installing detectors, checking monthly and maintaining a written record of the checks.

Risers on the septic tank must be chained and locked.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

**Doug Schaefer**  
**(608) 785-9679**