



Lodging Establishment Inspection Report

Establishment Information	
Facility Name LA CROSSE SETTLE INN	Facility Type Lodging 100-199 (LH3)
Facility ID # HSAT-7QXDWX	Facility Telephone # 608 781-5100
Facility Address 2110 ROSE ST LA CROSSE , WI 54603-2003	
Licensee Name LA CROSSE SETTLE INN LLC	Licensee Address 2110 ROSE ST LA CROSSE , SD 54603

Inspection Information		
Inspection Type Routine	Inspection Date 02/04/2016	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
Total # 1 Observed Violations - 46 - Smoke and Carbon Monoxide Detection OBSERVATION: Smoke detectors are absent or not in working order in rooms 254, 244, 210, 219. CORRECTIVE ACTION(S): Provide operational smoke detectors in all sleeping rooms and required locations. Correct By: 03-Mar-2016 CODE CITATION: DHS 195.14 (2) (c) Smoke detection. Each cabin or cottage shall be provided with at least one approved, listed and labeled smoke detector located in a manner consistent with the manufacturer's recommendations.

Comments
Rooms Inspected 126, 138, 143, 149, 254 246, 244, 223, 210, 219. Test all smoke detectors and check for expiration dates in all rooms and replace as necessary. Follow up inspection in one month.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

A re-inspection to assess your correction of these violations will be conducted on, or about,

Person in Charge

Aaron Greenwood

Sanitarian

Doug Schaefer
(608) 785-9679



Lodging Establishment Inspection Report

Establishment Information	
Facility Name LA CROSSE SETTLE INN	Facility Type Lodging 100-199 (LH3)
Facility ID # HSAT-7QXDWX	Facility Telephone # 608 781-5100
Facility Address 2110 ROSE ST LA CROSSE , WI 54603-2003	
Licensee Name LA CROSSE SETTLE INN LLC	Licensee Address 2110 ROSE ST LA CROSSE , SD 54603

Inspection Information		
Inspection Type Follow Up	Inspection Date 03/04/2016	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
Total # 0

Corrected Hazards
The following hazard(s) have been corrected since the last inspection. Total # 1 DHS 195.14 (2) (c) - SMOKE DETECTORS - REQUIREMENT OBSERVATION: Smoke detectors are absent or not in working order in rooms 254, 244, 210, 219. CORRECTIVE ACTION(S): Provide operational smoke detectors in all sleeping rooms and required locations. Correct By: 03-Mar-2016 CODE CITATION: DHS 195.14 (2) (c) Smoke detection. Each cabin or cottage shall be provided with at least one approved, listed and labeled smoke detector located in a manner consistent with the manufacturer's recommendations.

Comments
Smoke detectors identified as not working have been replaced and work is in progress to replace in all rooms.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

Doug Schaefer
(608) 785-9679