



Campground Establishment Inspection Report

| Establishment Information | |
|---|--|
| Facility Name VETERANS MEMORIAL CAMPGROUND | Facility Type Campground 101-199 Sites (RC4) |
| Facility ID # HSAT-7QWBK2 | Facility Telephone # 785-5903 |
| Facility Address N4668 COUNTY ROAD VP WEST SALEM , WI 54669 | |
| Licensee Name LACROSSE CO FACILITIES DEPT | Licensee Address 400 4TH ST N LA CROSSE , WI 54601 -3200 |

| Inspection Information | | |
|-----------------------------------|--------------------------------------|------------------|
| Inspection Type Routine | Inspection Date 09/19/2016 | Total Time Spent |

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

| Observed Violations |
|---|
| <p>Total # 2</p> <p>Observed Violations - 48 - Individual connections - backflow protection OBSERVATION: Water service connections noted lacking approved backflow prevention devices. CORRECTIVE ACTION(S): Provide water service connections with approved backflow prevention devices. Correct By: 19-Sep-2016 CODE CITATION: ATCP 79.14 (4) WATER SERVICE CONNECTIONS. (c) Water service connections shall be provided with approved backflow prevention devices.</p> <p>Observed Violations - 51 - POWTS access covers OBSERVATION: Sub surface pit access cover observed unsecured. CORRECTIVE ACTION(S): Secure access cover with a locking device. Correct By: 19-Sep-2016 CODE CITATION: ATCP 79.15 (1) POWTS. (c) POWTS access covers. The operator shall ensure that access opening covers to a POWTS are locked or secured, except for inspection, evaluation, maintenance or servicing purposes.</p> |

| Comments |
|--|
| <p>Contact Sam (785-9732) when corrected or with questions. Discontinue use of the "Y" connectors downstream of the hard-plumbed faucets at campsites, as the connectors are not approved plumbing fixtures.</p> |

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Mary Kaufmann

Sanitarian

Samuel Welch
(608) 785-9732