



Lodging Establishment Inspection Report

Establishment Information	
Facility Name WELCH MOTEL	Facility Type Lodging 5-30 Rooms (LH1)
Facility ID # ASTS-AG9SYQ	Facility Telephone # 608 788-1300
Facility Address 3643 MORMON COULEE RD LA CROSSE , WI 54601	
Licensee Name WELCH LLC	Licensee Address 3643 MORMON COULEE RD LA CROSSE , WI 54601

Inspection Information		
Inspection Type Pre-inspection Follow Up	Inspection Date 01/06/2017	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 1 Room: basement of office Observed Violations - 46 - Smoke and Carbon Monoxide Detection OBSERVATION: Carbon monoxide detector was not installed per manufacturer's directions. In the basement near the washing machine. CORRECTIVE ACTION(S): Install carbon monoxide detector in accordance with manufacturer's directions. Correct By: 09-Jan-2017 CODE CITATION: ATCP 72.145 (3) (e) The operator shall install every carbon monoxide detector required under this section according to the directions and specifications of the manufacturer of the carbon monoxide detector.</p>

Comments

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge


sally lince

Sanitarian


Aron Newberry
(608) 785-9730