



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name GUNDERSEN LUTHERAN - SPORTS MEDICINE	Facility Type Indoor Pool
Facility ID # ASTS-8NVSRM	Facility Telephone # 608 775-8600
Facility Address 3100 KINNEY COULEE RD S ONALASKA , WI 54650	
Licensee Name GUNDERSEN HEALTH SYSTEMS	Licensee Address 1836 SOUTH AVE LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	12.5
Combined Chlorine	-
pH	7.4
Alkalinity	70
Cyanuric Acid	-
Temperature	97
Flowmeter Reading(s)	60
Pressure Gauges Reading(s)	16

Inspection Information		
Inspection Type Routine	Inspection Date January 27, 2017	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
Total # 0

Comments
No violations noted at inspection. Contact Sam (785-9732) with questions. Pool is a Swimex and complies with VGBA requirements.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge


Marion Pahl

Sanitarian


Samuel Welch
(608) 785-9732