



## Recreational Water Establishment Inspection Report

<b>Establishment Information</b>	
Facility Name LA CROSSE COUNTRY CLUB	Facility Type Outdoor Pool
Facility ID # HSAT-7QWEY8	Facility Telephone # 608 781-5837
Facility Address 300 MARCOU ONALASKA, WI 54650	
Licensee Name LA CROSSE COUNTRY CLUB	Licensee Address 300 MARCOU RD ONALASKA, WI 54650

<b>Pool Parameters</b>	
Free Available Chlorine/Bromine	3.8
Combined Chlorine	0
pH	7.6
Alkalinity	90
Cyanuric Acid	55
Temperature	86
Flowmeter Reading(s)	550
Pressure Gauges Reading(s)	

<b>Inspection Information</b>		
Inspection Type Routine	Inspection Date August 10, 2016	Total Time Spent

**OPERATOR** - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

<b>Observed Violations</b>
<p><b>Total # 4</b></p> <p><b>Observed Violations - 08 - Recirculation rate-turnover</b>  <b>OBSERVATION:</b> The swimming pool or combination pool has a maximum turnover rate of greater than 6 hours. 600 GPM is necessary for pool, flowmeter was between 500-550.  <b>CORRECTIVE ACTION(S):</b> Immediately adjust or repair the equipment to operate at a proper turnover rate. Correct By: 10-Aug-2016  <b>CODE CITATION:</b> ATCP 76.11 Recirculation system. (4) PUMPS. The pump manufacturer's maintenance and operating instructions shall be followed. Recirculation pumps shall continuously achieve the designed pool water recirculation rate except during maintenance operations. The turnover</p>

time for pools shall be as follows:

(a) Swimming or combination pools. The maximum turnover time for a pool used for swimming or for a combination pool shall be 6 hours.

**Observed Violations - 11 - Chemicals - proper labeling and storage, no mixing of chemicals, smoking prohibited**

**OBSERVATION:** Material safety data sheets are not available for all chemicals used in the facility. MSDS sheets are not maintained in pool area or pump room.

**CORRECTIVE ACTION(S):** Provide material safety data sheets for all chemicals used in the facility. Correct By: 17-Aug-2016

**CODE CITATION:** ATCP 76.12 Labeling, storing, mixing, and handling chemicals. (4) HANDLING. (b) Material safety data sheet. Material safety data sheets shall be readily available at the pool attraction area for every chemical used.

**Observed Violations - 16 - pH alkalinity within limits or balanced, Cyanuric acid - within limits, Superoxidation - done as needed.**

**OBSERVATION:** The cyanuric acid concentration is 55.

**CORRECTIVE ACTION(S):** Lower the concentration of cyanuric acid to 30 ppm or lower. Correct By: 10-Aug-2016

**CODE CITATION:** ATCP 76.14 Disinfectant feeding and residuals. (4) CHEMICAL CONCENTRATIONS AND RESIDUALS. (b) Cyanurates. The water cyanuric acid concentration may not exceed 30 ppm.

**Observed Violations - 29 - Facility maintenance and equipment - Pool and deck area - good repair, sanitation, maintained, depth markings, boundary line, drinking fountain**

**OBSERVATION:** The drinking fountain is not clean. Accumulation of mold/algae in drains.

**CORRECTIVE ACTION(S):** Clean the drinking fountain and keep it clean. Correct By: 17-Aug-2016

**CODE CITATION:** ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (b) Deck maintenance and cleaning. Pool areas and appurtenances, including safety pads, shall be maintained in good repair and shall be rinsed daily to prevent microbial growth. Indoor pool decks shall be disinfected at least weekly. Depth markings along the edge of the pool shall be maintained to be clearly visible and readable. The deck shall be kept unobstructed except for easily portable furniture and equipment.

**Comments**

[large pool](#)

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

**Nicole Frankfourth  
(608) 785-9731**



## Recreational Water Establishment Inspection Report

<b>Establishment Information</b>	
Facility Name LA CROSSE COUNTRY CLUB	Facility Type Outdoor Pool
Facility ID # HSAT-7QWEY8	Facility Telephone # 608 781-5837
Facility Address 300 MARCOU ONALASKA, WI 54650	
Licensee Name LA CROSSE COUNTRY CLUB	Licensee Address 300 MARCOU RD ONALASKA, WI 54650

<b>Pool Parameters</b>	
Free Available Chlorine/Bromine	3.6
Combined Chlorine	0
pH	7.6
Alkalinity	110
Cyanuric Acid	40
Temperature	85
Flowmeter Reading(s)	Unknown
Pressure Gauges Reading(s)	10

<b>Inspection Information</b>		
Inspection Type Routine	Inspection Date August 10, 2016	Total Time Spent

**OPERATOR** - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

<b>Observed Violations</b>
<p><b>Total # 3</b></p> <p><b>Observed Violations - 09 - Gauges and flowmeters maintained, operated, accurate, installed, approved pressure or vacuum</b>  <b>OBSERVATION:</b> The flowmeter is not operational.  <b>CORRECTIVE ACTION(S):</b> Repair or replace the specified equipment so an accurate reading can be recorded. Correct By: 17-Aug-2016  <b>CODE CITATION:</b> ATCP 76.11 Recirculation system. (5) FLOWMETERS, VALVES, AND GAUGES. Flowmeters, valves and gauges shall be maintained in operating condition.</p>

**Observed Violations - 16 - pH alkalinity within limits or balanced, Cyanuric acid - within limits, Superoxidation - done as needed.**

**OBSERVATION:** The cyanuric acid concentration is 50ppm.

**CORRECTIVE ACTION(S):** Lower the concentration of cyanuric acid to 30 ppm or lower. Correct By: 10-Aug-2016

**CODE CITATION:** ATCP 76.14 Disinfectant feeding and residuals. (4) CHEMICAL CONCENTRATIONS AND RESIDUALS. (b) Cyanurates. The water cyanuric acid concentration may not exceed 30 ppm.

**Observed Violations - 25 - Lifeguards identifiable, no distracting duties, at duties station, certifications verified**

**OBSERVATION:** Lifeguard certifications are not available in lifeguard room during inspection. PIC was not aware where they are kept for review. Pool was not lifeguarded at time of inspection.

**CORRECTIVE ACTION(S):** The lifeguard must be relieved of duties until a current certification can be verified. If the minimum lifeguard requirements in the approved staffing plan are not met as a result, the guarded pool or portion must be closed. Correct By: 10-Aug-2016

**CODE CITATION:** ATCP 76.22 Lifeguards and Attendants. (2) QUALIFICATIONS. (a) A copy of each lifeguarding certification, first aid certification, and CPR certification held by lifeguard staff shall be maintained at the pool and shall be made available for inspection by the department.

**Comments**

[Small pool](#)  
[Taylor 2006 test kit](#)

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

**Nicole Frankfourth**  
**(608) 785-9731**