



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name BRONSTON CHIROPRACTIC	Facility Type Indoor Pool
Facility ID # HSAT-7QXFZF	Facility Telephone # 608 782-2225
Facility Address 1122 SAINT ANDREW ST LA CROSSE, WI 54603	
Licensee Name BRONSTON LEO	Licensee Address 1122 SAINT ANDREW ST LA CROSSE, WI 54603

Pool Parameters	
Free Available Chlorine/Bromine	10
Combined Chlorine	
pH	7.8
Alkalinity	170
Cyanuric Acid	
Temperature	100
Flowmeter Reading(s)	65
Pressure Gauges Reading(s)	13

Inspection Information		
Inspection Type Routine	Inspection Date May 12, 2016	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 5</p> <p>Observed Violations - 30 - Toilet, shower, dressing rooms, provided as needed, clean maintained, hand drying, toilet tissue, suits, caps, or towels provided to patrons - clean, thoroughly laundered, storage</p> <p>OBSERVATION: The soap dispenser in women's restroom shower is empty.</p> <p>CORRECTIVE ACTION(S): Provide soap at all hand washing sinks and showers. Correct By: 12-May-2016</p> <p>CODE CITATION: DHS 172.33 Facility maintenance, repair and sanitation. (2) SHOWER, TOILET AND DRESSING FACILITIES. (e) Soap shall be continually provided at each hand washing sink and shower</p>

in permanently installed dispensing devices. The dispensers shall be maintained in operating condition.

Observed Violations - 05 - Water level maintained, Proportional flow - gutter or skimmers versus drain

REPEAT OBSERVATION: The skimmer to main drain flow ration is not set correctly. Both were 100% open at time of inspection.

CORRECTIVE ACTION(S): Readjust the flow so that only 20% comes through the main drain and 80% comes through the skimmers. Correct By: 12-May-2016

CODE CITATION: DHS 172.11 Recirculation system. (2) SKIMMERS AND RECIRCULATION FLOW. (a) The flow through each skimmer shall be adjusted as often as necessary to maintain a vigorous skimming action at each skimmer. The pool water level shall be maintained at an elevation so that continuous effective surface skimming is accomplished through skimmers or over the gutter lip. For gutter pools, approximately 75% of the required recirculation flow shall be through the gutter and 25% through the main drain during normal operation. For pools with skimmers, approximately 80% of the recirculation flow shall be through skimmers and 20% through the main drain. For reverse flow pools, 100% of the required circulation shall be through the gutter or skimmer.

Observed Violations - 04 - Skimmers, gutters, drains, water inlets - number, clean, good repair, installed, operated

OBSERVATION: Skimmer basket noted with algae/dirt on basket.

CORRECTIVE ACTION(S): Maintain in a clean condition. Correct By: 12-May-2016

CODE CITATION: DHS 172.11 Recirculation system. (2) (b) Skimmers, skimmer weirs, and overflow gutters and drains shall be maintained so that they are clean and shall be repaired or replaced as needed. Skimmer covers shall be securely seated on deck.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: A first aid kit is not available in the pool area.

CORRECTIVE ACTION(S): Provide a first aid kit in the pool area or comparable compliance. Correct By: 12-May-2016

CODE CITATION: DHS 172.27 First aid supplies. (1) A first aid kit of a sort approved by the department and 2 durable blankets in good condition shall be available at each pool area. The first aid kit shall contain all of the following items:

1. Gauze pads - 4" x 4",
2. Gauze pads - 8" x 10",
3. Adhesive bandages,
4. Triangular bandages,
5. Scissors,
6. Gauze roller bandage,
7. Tweezers,
8. Adhesive tape,
9. Eye wash,
10. Elastic bandage,
11. Disposable surgical gloves,
12. Resuscitation pocket face mask,
13. Instant cold packs.

Observed Violations - 30 - Toilet, shower, dressing rooms, provided as needed, clean maintained, hand drying, toilet tissue, suits, caps, or towels provided to patrons - clean, thoroughly laundered, storage

OBSERVATION: Floor tile in men's restroom is cracked and broken near shower.

CORRECTIVE ACTION(S): Keep toilet room fixtures maintained in good repair. Correct By: 12-Jun-2016

CODE CITATION: DHS 172.33 Facility maintenance, repair and sanitation. (2) SHOWER, TOILET AND DRESSING FACILITIES. (c) Toilet room fixtures and diaper changing stations shall be kept clean and maintained in good repair.

Comments

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

Tamara

Nicole Frankfourth

Nicole Frankfourth
(608) 785-9731