



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name ONALASKA COMFORT INN	Facility Type Indoor Pool
Facility ID # HSAT-7QXGEE	Facility Telephone # 608 781-7500
Facility Address 1223 CROSSING MEADOWS DR ONALASKA , WI 54650	
Licensee Name W2005/FARGO HOTELS (POOL C) REALTY LLP	Licensee Address 6031 CONNECTION DR HOSP #500 IRVING , TX 75039

Pool Parameters	
Free Available Chlorine/Bromine	3.6
Combined Chlorine	0.6
pH	7.6
Alkalinity	110
Cyanuric Acid	
Temperature	88
Flowmeter Reading(s)	55
Pressure Gauges Reading(s)	19

Inspection Information		
Inspection Type Routine	Inspection Date 02/18/2016	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 2

Observed Violations - 31 - General maintenance, walls, ceilings, floors, hosing spectator area separated, maintained, no hazardous conditions, adequate lighting accessibility, solid waste, garbage storage and disposal.

OBSERVATION: The VGBA-approved grates are not being replaced as necessary. The grates were to be replaced by December 2014, per manufacturer.

CORRECTIVE ACTION(S): Repair and maintain all equipment pursuant to DHS 172.33(1)(e). Correct By: 17-Feb-2017

CODE CITATION: DHS 172.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (e) Equipment. Pool equipment, including equipment on the deck, shall be properly located and installed and maintained and repaired as necessary.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: The pool operator number and facility location are not posted near the designated emergency phone.

CORRECTIVE ACTION(S): Post the pool operator number and facility location near the designated emergency phone. Correct By: 18-Feb-2016

CODE CITATION: DHS 172.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. DHS 173.02 (2).

Comments

Contact Sam (785-9732) with questions. Signed Virginia Graehme Baker Act compliance statement is on hand and in file. Drain cover lifespan documentation is on hand.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Ashley Nau

Sanitarian



Samuel Welch
(608) 785-9732