



Recreational Water Establishment Inspection Report

| <b>Establishment Information</b>                                      |  |
|---|--|
| Facility Name<br><b>CAMP DECORAH</b>                                  | Facility Type<br><b>Outdoor Pool</b>                                   |
| Facility ID #<br><b>HSAT-7QWJTR</b>                                   | Facility Telephone #<br><b>608 526-6418</b>                            |
| Facility Address<br><b>W7520 COUNCIL BAY RD<br/>HOLMEN , WI 54636</b> |  |
| Licensee Name<br><b>GATEWAY AREA COUNCIL INC</b>                      | Licensee Address<br><b>2600 QUARRY RD<br/>LA CROSSE , WI<br/>54601</b> |

| <b>Pool Parameters</b>          |     |
|---------------------------------|-----|
| Free Available Chlorine/Bromine | 2.0 |
| Combined Chlorine               | 0.2 |
| pH                              | 7.8 |
| Alkalinity                      | 70  |
| Cyanuric Acid                   |     |
| Temperature                     | 79  |
| Flowmeter Reading(s)            | 150 |
| Pressure Gauges Reading(s)      |     |

| <b>Inspection Information</b>     |                                      |                  |
|-----------------------------------|--------------------------------------|------------------|
| Inspection Type<br><b>Routine</b> | Inspection Date<br><b>06/16/2016</b> | Total Time Spent |

**OPERATOR** - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

**Observed Violations**

**Total # 2**

**Observed Violations - 24 - Lifeguard staffing plans - if required - approved, verified, accurate, accessible, maintained and used.**

**REPEAT OBSERVATION:** The facility does not have a lifeguard and attendant staffing plan.

**CORRECTIVE ACTION(S):** Create a written plan pursuant to the requirements of DHS 172.22 and submit it for approval. Correct By: 16-Jun-2016

**CODE CITATION:** DHS 172.22 Lifeguards and Attendants. (1) LIFEGUARD AND ATTENDANT STAFFING PLANS. (a) The owner or operator of a pool, including a whirlpool over 4 feet deep and a pool with a visual obstruction, and the owner or operator of a water attraction or water attraction complex shall submit a written, proposed lifeguard and attendant staffing plan to the department or the department's agent for approval. The owner or operator shall keep a copy of the plan at the pool. The plan shall include all of the following:

1. The square footage of the pool, water attraction, and water attraction complex as applicable.
2. The maximum and average patron load.
3. The hours of operation.
4. The location of each lifeguard station and each first aid station.
5. The number of lifeguards or attendants on duty pursuant to DHS 172.23.
6. A diagram of the facility that indicates the placement of attendants, lifeguards, chairs and stations for both average and maximum patron capacity. The diagram shall include each obstruction.
7. A method of communication when 2 or more attendants or lifeguards are required for a water attraction.

**Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.**

**OBSERVATION:** "NO DIVING" is not posted in the pool rules.

**CORRECTIVE ACTION(S):** Post signage in compliance with DHS 172.29(1)(c). Correct By: 16-Jun-2016

**CODE CITATION:** DHS 172.29 Posting pool and water attraction rules. (1) GENERAL. (c) A pool that is 200 square feet in area or greater that does not have an approved diving well configuration shall have "NO DIVING" signs in at least 4-inch high letters included with the rules listed under par. (b).

**Comments**

[Tighten the 3 stair handles, add one soap dispenser in the shower.](#)

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

**Doug Schaefer  
(608) 785-9679**