



## Recreational Water Establishment Inspection Report

<b>Establishment Information</b>	
Facility Name ECONOLOGGE	Facility Type Indoor Pool
Facility ID # HSAT-7QXBCL	Facility Telephone # 608 781-0200
Facility Address 1906 ROSE ST LA CROSSE, WI 54603	
Licensee Name DRAGAN INC	Licensee Address 1112 PARKRIDGE DR ONALASKA, WI 54650

<b>Pool Parameters</b>	
Free Available Chlorine/Bromine	18.75
Combined Chlorine	
pH	7.6
Alkalinity	100
Cyanuric Acid	NA
Temperature	103
Flowmeter Reading(s)	90
Pressure Gauges Reading(s)	18

<b>Inspection Information</b>		
Inspection Type Routine	Inspection Date March 02, 2016	Total Time Spent

**OPERATOR** - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

<b>Observed Violations</b>
<p><b>Total # 7</b></p> <p><b>Observed Violations - 11 - Chemicals - proper labeling and storage, no mixing of chemicals, smoking prohibited</b>  <b>REPEAT OBSERVATION:</b> Material safety data sheets are not available for all chemicals used in the facility. Only MSDS for brominating tablets are available in pool room.  <b>CORRECTIVE ACTION(S):</b> Provide material safety data sheets for all chemicals used in the facility.            Correct By: 09-Mar-2016  <b>CODE CITATION:</b> DHS 172.12 Labeling, storing, mixing, and handling chemicals. (4) HANDLING. (b) Material safety data sheet. Material safety data sheets shall be readily available at the pool attraction</p>

area for every chemical used.

**Observed Violations - 20 - Approved test kits available, maintained, used, frequency of testing - 2X/day-pools, 4x/day-whirlpools alkalinity, cyanuric acid, and combined chlorine done as required.**

**OBSERVATION:** The water testing frequency for alkalinity is not in compliance with DHS 172.18(2).

**CORRECTIVE ACTION(S):** Perform water testing in accordance with DHS 172.18(2). Test alkalinity weekly.

**CODE CITATION:** DHS 172.18 Water testing frequency. (2) Except as specified under sub. (3) water in a whirlpool, therapy pool, or exercise pool shall be tested for pH and disinfectant residual before the pool is open to the public or before the pool is in use and at least 4 times daily. For at least 2 of these times, the testing shall be done when the pool is in use. Water shall be tested at least once daily for combined chlorine, when chlorine is used, and at least weekly for total alkalinity.

**Observed Violations - 31 - General maintenance, walls, ceilings, floors, hosing spectator area separated, maintained, no hazardous conditions, adequate lighting accessibility, solid waste, garbage storage and disposal.**

**OBSERVATION:** The garbage containers in pool room does not have a lid.

**CORRECTIVE ACTION(S):** Acquire tight-fitting lids for the garbage containers. Correct By: 09-Mar-2016

**CODE CITATION:** DHS 172.33 Facility maintenance, repair and sanitation. (3) GARBAGE AND REFUSE. All garbage and refuse shall be stored in metal or rigid plastic containers having tight-fitting lids. A sufficient number of containers shall be provided for all garbage and refuse generated. Filled containers of garbage or refuse shall be covered and stored in a manner to prevent harborage for rodents, insect attraction and breeding areas, odors, environmental pollution and accidents. The contents of the containers shall be disposed of as needed and in a sanitary manner. All containers shall be kept clean and maintained in good repair.

**Observed Violations - 05 - Water level maintained, Proportional flow - gutter or skimmers versus drain**

**OBSERVATION:** The skimmer to main drain flow ration is not set correctly. Skimmers set at 100% open, and drain set at 50% open.

**CORRECTIVE ACTION(S):** Readjust the flow so that only 20% comes through the main drain and 80% comes through the skimmers. Correct By: 02-Mar-2016

**CODE CITATION:** DHS 172.11 Recirculation system. (2) SKIMMERS AND RECIRCULATION FLOW. (a) The flow through each skimmer shall be adjusted as often as necessary to maintain a vigorous skimming action at each skimmer. The pool water level shall be maintained at an elevation so that continuous effective surface skimming is accomplished through skimmers or over the gutter lip. For gutter pools, approximately 75% of the required recirculation flow shall be through the gutter and 25% through the main drain during normal operation. For pools with skimmers, approximately 80% of the recirculation flow shall be through skimmers and 20% through the main drain. For reverse flow pools, 100% of the required circulation shall be through the gutter or skimmer.

**Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted**

**OBSERVATION:** The emergency telephone does not work.

**CORRECTIVE ACTION(S):** Provide a functional emergency telephone immediately. Correct By: 04-Mar-2016

**CODE CITATION:** DHS 172.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. DHS 173.02 (2).

**Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted**

**OBSERVATION:** A first aid kit is not available in the pool area. Rules state First Aid Kit is available at front desk, but first aid kit there is not fully stocked.

**CORRECTIVE ACTION(S):** Provide a first aid kit in the pool area. Correct By: 09-Mar-2016

**CODE CITATION:** DHS 172.27 First aid supplies. (1) A first aid kit of a sort approved by the department and 2 durable blankets in good condition shall be available at each pool area. The first aid kit shall contain all of the following items:

1. Gauze pads - 4" x 4", 2. Gauze pads - 8" x 10", 3. Adhesive bandages, 4. Triangular bandages, 5. Scissors, 6. Gauze roller bandage, 7. Tweezers, 8. Adhesive tape, 9. Eye wash, 10. Elastic bandage, 11. Disposable surgical gloves, 12. Resuscitation pocket face mask, 13. Instant cold packs.

**Observed Violations - 04 - Skimmers, gutters, drains, water inlets - number, clean, good repair, installed, operated**

**OBSERVATION:** Replace all components of Aquastar drain covers before next routine inspection.

**CORRECTIVE ACTION(S):** Secure covers so they are not easily removed. Provide documentation of new covers to Nicole. Correct By: 02-Mar-2017

**CODE CITATION:** DHS 172.11 Recirculation system. (2) (b) Skimmers, skimmer weirs, and overflow gutters and drains shall be maintained so that they are clean and shall be repaired or replaced as needed. Skimmer covers shall be securely seated on deck.

**Comments**

[Followup will be conducted in 30 days.](#)

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Sanitarian



**Nicole Frankfourth**  
**(608) 785-9731**