



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name CAMP EHAWEE	Facility Type Outdoor Pool
Facility ID # BSAW-86PHB8	Facility Telephone # 608
Facility Address N9559 WILD RD MINDORO , WI 54644	
Licensee Name GIRL SCOUTS OF WISCONSIN- BADGERLAND INC	Licensee Address 2710 SKI LN MADISON , WI 53713

Pool Parameters	
Free Available Chlorine/Bromine	2
Combined Chlorine	0
pH	7.4
Alkalinity	80
Cyanuric Acid	
Temperature	80
Flowmeter Reading(s)	
Pressure Gauges Reading(s)	10/18

Inspection Information		
Inspection Type Routine	Inspection Date 07/25/2016	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 16</p> <p>Observed Violations - 04 - Skimmers, gutters, drains, water inlets - number, clean, good repair, installed, operated</p> <p>OBSERVATION: There are 4 skimmers with no or little flow, skimmer is not adequately removing surface debris.</p> <p>CORRECTIVE ACTION(S): Readjust the flow through the skimmers to maintain vigorous skimming action through all skimmers. Check lines for obstruction. Correct By: 25-Jul-2016</p> <p>CODE CITATION: ATCP 76.11 Recirculation system. (2) SKIMMERS AND RECIRCULATION FLOW.</p> <p>(a) The flow through each skimmer shall be adjusted as often as necessary to maintain a vigorous skimming action at each skimmer. The pool water level shall be maintained at an elevation so that continuous effective surface skimming is accomplished through skimmers or over the gutter lip. For gutter pools, approximately 75% of the required recirculation flow shall be through the gutter and 25% through the main drain during normal operation. For pools with skimmers, approximately 80% of the recirculation flow shall be through skimmers and 20% through the main drain. For reverse flow pools, 100% of the required circulation shall be through the gutter or skimmer.</p> <p>Observed Violations - 11 - Chemicals - proper labeling and storage, no mixing of chemicals, smoking prohibited</p> <p>OBSERVATION: Chemicals are not stored in accordance with ATCP 76.12(2). Muriatic acid stored in the guard room and pumped to injection in pump room.</p> <p>CORRECTIVE ACTION(S): Store chemicals in accordance with ATCP 76.12(2). Correct By: 25-Jul-2016</p>

CODE CITATION: DHS 172.12 Labeling, storing, mixing, and handling chemicals. (2) STORAGE. Chemicals shall be stored in the original or a properly-labeled container, which shall be covered and kept in a clean, dry, well ventilated and locked area away from flammables, incompatible chemicals, and heat sources. Only authorized personnel shall have access to the storage area. Chemicals may not be stored in chlorine gas storage areas. Food may not be stored in the chemical storage area. Smoking is prohibited in the chemicals storage area.

Observed Violations - 31 - General maintenance, walls, ceilings, floors, hosing spectator area separated, maintained, no hazardous conditions, adequate lighting accessibility, solid waste, garbage storage and disposal.

OBSERVATION: Guard room is not clean and sanitary, spilled product on floor and unclean.

CORRECTIVE ACTION(S): Maintain the walls, ceilings, and floors in a clean and sanitary condition. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (c) Walls, ceilings and floors. The walls, ceilings and floors in the pool area shall be maintained in a clean and sanitary condition.

Observed Violations - 31 - General maintenance, walls, ceilings, floors, hosing spectator area separated, maintained, no hazardous conditions, adequate lighting accessibility, solid waste, garbage storage and disposal.

OBSERVATION: Guard deck chairs have been removed and mounts, holes and some cut off pipes were left on the deck. Maintained and repair as necessary.

CORRECTIVE ACTION(S): Repair and maintain all equipment pursuant to ATCP 76.33(1)(e). Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (e) Equipment. Pool equipment, including equipment on the deck, shall be properly located and installed and maintained and repaired as necessary.

Observed Violations - 30 - Toilet, shower, dressing rooms, provided as needed, clean maintained, hand drying, toilet tissue, suits, caps, or towels provided to patrons - clean, thoroughly laundered, storage

OBSERVATION: The soap dispenser staff shower and men's rest room are empty.

CORRECTIVE ACTION(S): Provide soap at all hand washing sinks and showers. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (2) SHOWER, TOILET AND DRESSING FACILITIES. (e) Soap shall be continually provided at each hand washing sink and shower in permanently installed dispensing devices. The dispensers shall be maintained in operating condition.

Observed Violations - 30 - Toilet, shower, dressing rooms, provided as needed, clean maintained, hand drying, toilet tissue, suits, caps, or towels provided to patrons - clean, thoroughly laundered, storage

OBSERVATION: No hand towels are available at the men's or girls restrooms hand washing sink.

CORRECTIVE ACTION(S): Provide hand drying provisions at all hand washing sinks. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (2) SHOWER, TOILET AND DRESSING FACILITIES. (f) Individual towels in dispensers or hot air dryers shall be provided at hand washing sinks.

Observed Violations - 24 - Lifeguard staffing plans - if required - approved, verified, accurate, accessible, maintained and used.

OBSERVATION: The facility does not have a lifeguard and attendant staffing plan.

CORRECTIVE ACTION(S): Create a written plan pursuant to the requirements of ATCP 76.22 and submit it for approval. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.22 Lifeguards and Attendants. (1) LIFEGUARD AND ATTENDANT STAFFING PLANS. (a) The owner or operator of a pool, including a whirlpool over 4 feet deep and a pool with a visual obstruction, and the owner or operator of a water attraction or water attraction complex shall submit a written, proposed lifeguard and attendant staffing plan to the department or the department's agent for approval. The owner or operator shall keep a copy of the plan at the pool. The plan shall include all of the following:

1. The square footage of the pool, water attraction, and water attraction complex as applicable.
2. The maximum and average patron load.
3. The hours of operation.
4. The location of each lifeguard station and each first aid station.
5. The number of lifeguards or attendants on duty pursuant to ATCP 76.23.
6. A diagram of the facility that indicates the placement of attendants, lifeguards, chairs and stations for both average and maximum patron capacity. The diagram shall include each obstruction.
7. A method of communication when 2 or more attendants or lifeguards are required for a water attraction.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: There is no emergency telephone.

CORRECTIVE ACTION(S): Provide a functional emergency telephone immediately. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted

near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Observed Violations - 29 - Facility maintenance and equipment - Pool and deck area - good repair, sanitation, maintained, depth markings, boundary line, drinking fountain

OBSERVATION: The deck and appurtenances are not being cleaned and sanitized regularly.

CORRECTIVE ACTION(S): Clean and sanitize the deck and appurtenances according to ATCP 76.33 (1)(b).

Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (b) Deck maintenance and cleaning. Pool areas and appurtenances, including safety pads, shall be maintained in good repair and shall be rinsed daily to prevent microbial growth. Indoor pool decks shall be disinfected at least weekly. Depth markings along the edge of the pool shall be maintained to be clearly visible and readable. The deck shall be kept unobstructed except for easily portable furniture and equipment.

Observed Violations - 29 - Facility maintenance and equipment - Pool and deck area - good repair, sanitation, maintained, depth markings, boundary line, drinking fountain

OBSERVATION: The drinking fountain is not functional.

CORRECTIVE ACTION(S): Repair the drinking fountain. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (g) Drinking fountain. Each drinking fountain required under s. SPS 390.19 shall be maintained in clean and sanitary condition.

Observed Violations - 34 - Security - pool enclosure, controlled access, self-closing gates and latches access through bathhouse fencing safety rope as required.

OBSERVATION: The doors to the pool enclosure is not self-closing or latching.

CORRECTIVE ACTION(S): Repair the door immediately so that it is self-closing and latching. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.34 Pool design. (4) All pool areas shall be enclosed and have self-closing and latching gates or doors that are lockable.

Observed Violations - 04 - Skimmers, gutters, drains, water inlets - number, clean, good repair, installed, operated

OBSERVATION: Three skimmers with stuck weirs.

CORRECTIVE ACTION(S): Replace or change style of weir. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.11 Recirculation system. (2) (b) Skimmers, skimmer weirs, and overflow gutters and drains shall be maintained so that they are clean and shall be repaired or replaced as needed. Skimmer covers shall be securely seated on deck.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: 2 durable blankets are not available in the pool area.

Missing first aid kit.

CORRECTIVE ACTION(S): Provide 2 durable blankets in the pool area.

Provide supplied first aid kit. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.27 First aid supplies. (1) A first aid kit of a sort approved by the department and 2 durable blankets in good condition shall be available at each pool area. The first aid kit shall contain all of the following items:

1. Gauze pads - 4" x 4", 2. Gauze pads - 8" x 10", 3. Adhesive bandages, 4. Triangular bandages, 5. Scissors, 6. Gauze roller bandage, 7. Tweezers, 8. Adhesive tape, 9. Eye wash, 10. Elastic bandage, 11. Disposable surgical gloves, 12. Resuscitation pocket face mask, 13. Instant cold packs.

Observed Violations - 27 - Pool rules enforced - communicable disease, showers, food, glass, animals prohibited. Maximum patron loading posted, legible, located, Maximum pool attendance posted, closing criteria followed.

OBSERVATION: The following rules are missing from the posting: [rules].

CORRECTIVE ACTION(S): Provide a sign in compliance with ATCP 76.29(1)(b). Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (b) A legible sign showing pool use rules shall be posted in a conspicuous place or places in the pool area. The sign shall include at least all of the rules in this paragraph in letters at least one inch high. Pool rules in connection with water attractions, therapy pools or other specialized pools defined in s. SPS 390 or this chapter may not be eliminated or modified without approval by the department.

1. Do not enter the pool if you have a communicable disease or an open cut.
2. Do not bring food, drink, gum or tobacco into the pool.
3. Shower before entering the pool and after use of toilet facilities.
4. Do not run or engage in rough play in the pool area.
5. Do not bring animals into the pool area.
6. Diaper changing on the pool deck is prohibited.
7. Glass and shatterable items are prohibited in the pool area.

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone

present, located, good condition, phone numbers posted

OBSERVATION: The emergency telephone is not in the enclosure.

CORRECTIVE ACTION(S): Provide a functional emergency telephone in the enclosure. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.03 (2).

Observed Violations - 26 - Permissible patron load, Rescue equipment, first aid equipment, telephone present, located, good condition, phone numbers posted

OBSERVATION: The emergency numbers are not posted near the designated emergency phone.

CORRECTIVE ACTION(S): Post the emergency numbers near the designated emergency phone. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Comments

[Recommend having shock on hand \(none here today\).](#)

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

A re-inspection to assess your correction of these violations will be conducted on, or about,

Person in Charge

Sanitarian

Doug Schaefer
(608) 785-9679



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name CAMP EHAWEE	Facility Type Outdoor Pool
Facility ID # BSAW-86PHB8	Facility Telephone # 608
Facility Address N9559 WILD RD MINDORO , WI 54644	
Licensee Name GIRL SCOUTS OF WISCONSIN- BADGERLAND INC	Licensee Address 2710 SKI LN MADISON , WI 53713

Pool Parameters	
Free Available Chlorine/Bromine	3.6
Combined Chlorine	0
pH	7.2
Alkalinity	
Cyanuric Acid	
Temperature	
Flowmeter Reading(s)	
Pressure Gauges Reading(s)	

Inspection Information		
Inspection Type Follow Up	Inspection Date 08/04/2016	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
Total # 0

Corrected Hazards
<p>The following hazard(s) have been corrected since the last inspection.</p> <p>Total # 16</p> <p>ATCP 76.11(2)(a) - SKIMMERS NOT FUNCTIONING</p> <p>OBSERVATION: There are 4 skimmers with no or little flow, skimmer is not adequately removing surface debris.</p> <p>CORRECTIVE ACTION(S): Readjust the flow through the skimmers to maintain vigorous skimming action through all skimmers. Check lines for obstruction. Correct By: 25-Jul-2016</p> <p>CODE CITATION: ATCP 76.11 Recirculation system. (2) SKIMMERS AND RECIRCULATION FLOW.</p> <p>(a) The flow through each skimmer shall be adjusted as often as necessary to maintain a vigorous skimming action at each skimmer. The pool water level shall be maintained at an elevation so that continuous effective surface skimming is accomplished through skimmers or over the gutter lip. For gutter pools, approximately 75% of the required recirculation flow shall be through the gutter and 25% through the main drain during normal operation. For pools with skimmers, approximately 80% of the recirculation flow shall be through skimmers and 20% through the main drain. For reverse flow pools, 100% of the required circulation shall be through the gutter or skimmer.</p> <p>ATCP 76.12(2) - CHEMICAL STORAGE</p>

OBSERVATION: Chemicals are not stored in accordance with ATCP 76.12(2). Muriatic acid stored in the guard room and pumped to injection in pump room.

CORRECTIVE ACTION(S): Store chemicals in accordance with ATCP 76.12(2). Correct By: 25-Jul-2016

CODE CITATION: DHS 172.12 Labeling, storing, mixing, and handling chemicals. (2) STORAGE. Chemicals shall be stored in the original or a properly-labeled container, which shall be covered and kept in a clean, dry, well ventilated and locked area away from flammables, incompatible chemicals, and heat sources. Only authorized personnel shall have access to the storage area. Chemicals may not be stored in chlorine gas storage areas. Food may not be stored in the chemical storage area. Smoking is prohibited in the chemicals storage area.

ATCP 76.33(1)(c) - WALLS, CEILING, FLOORS NOT CLEAN

OBSERVATION: Guard room is not clean and sanitary, spilled product on floor nd unclean.

CORRECTIVE ACTION(S): Maintain the walls, ceilings, and floors in a clean and sanitary condition. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (c) Walls, ceilings and floors. The walls, ceilings and floors in the pool area shall be maintained in a clean and sanitary condition.

ATCP 76.33(1)(e) - EQUIPMENT NOT MAINTAINED

OBSERVATION: Guard deck chairs have been removed and mounts, holes and some cut off pipes were left on the deck. Maintained and repair as necessary.

CORRECTIVE ACTION(S): Repair and maintain all equipment pursuant to ATCP 76.33(1)(e). Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (e) Equipment. Pool equipment, including equipment on the deck, shall be properly located and installed and maintained and repaired as necessary.

ATCP 76.33(2)(e) - OUT OF SOAP

OBSERVATION: The soap dispenser staff shower and men's rest room are empty.

CORRECTIVE ACTION(S): Provide soap at all hand washing sinks and showers. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (2) SHOWER, TOILET AND DRESSING FACILITIES. (e) Soap shall be continually provided at each hand washing sink and shower in permanently installed dispensing devices. The dispensers shall be maintained in operating condition.

ATCP 76.33(2)(f) - OUT OF HAND TOWELS

OBSERVATION: No hand towels are available at the men's or girls restrooms hand washing sink.

CORRECTIVE ACTION(S): Provide hand drying provisions at all hand washing sinks. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (2) SHOWER, TOILET AND DRESSING FACILITIES. (f) Individual towels in dispensers or hot air dryers shall be provided at hand washing sinks.

[A] ATCP 76.22(1)(a) - LIFEGUARD AND ATTENDANT STAFFING PLAN

OBSERVATION: The facility does not have a lifeguard and attendant staffing plan.

CORRECTIVE ACTION(S): Create a written plan pursuant to the requirements of ATCP 76.22 and submit it for approval. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.22 Lifeguards and Attendants. (1) LIFEGUARD AND ATTENDANT STAFFING PLANS. (a) The owner or operator of a pool, including a whirlpool over 4 feet deep and a pool with a visual obstruction, and the owner or operator of a water attraction or water attraction complex shall submit a written, proposed lifeguard and attendant staffing plan to the department or the department's agent for approval. The owner or operator shall keep a copy of the plan at the pool. The plan shall include all of the following:

1. The square footage of the pool, water attraction, and water attraction complex as applicable.
2. The maximum and average patron load.
3. The hours of operation.
4. The location of each lifeguard station and each first aid station.
5. The number of lifeguards or attendants on duty pursuant to ATCP 76.23.
6. A diagram of the facility that indicates the placement of attendants, lifeguards, chairs and stations for both average and maximum patron capacity. The diagram shall include each obstruction.
7. A method of communication when 2 or more attendants or lifeguards are required for a water attraction.

[A] ATCP 76.26(2) - TELEPHONE NOT WORKING

OBSERVATION: There is no emergency telephone.

CORRECTIVE ACTION(S): Provide a functional emergency telephone immediately. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

[A] ATCP 76.33(1)(b) - DECK DISINFECTION

OBSERVATION: The deck and appurtenances are not being cleaned and sanitized regularly.

CORRECTIVE ACTION(S): Clean and sanitize the deck and appurtenances according to ATCP 76.33 (1)(b).
Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (b) Deck maintenance and cleaning. Pool areas and appurtenances, including safety pads, shall be maintained in good repair and shall be rinsed daily to prevent microbial growth. Indoor pool decks shall be disinfected at least weekly. Depth markings along the edge of the pool shall be maintained to be clearly visible and readable. The deck shall be kept unobstructed except for easily portable furniture and equipment.

[A] ATCP 76.33(1)(g) - DRINKING FOUNTAIN NOT FUNCTIONAL

OBSERVATION: The drinking fountain is not functional.

CORRECTIVE ACTION(S): Repair the drinking fountain. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.33 Facility maintenance, repair and sanitation. (1) POOL AREA. (g) Drinking fountain. Each drinking fountain required under s. SPS 390.19 shall be maintained in clean and sanitary condition.

[A] ATCP 76.34(4) - SELF-CLOSING AND LATCHING GATES

OBSERVATION: The doors to the pool enclosure is not self-closing or latching.

CORRECTIVE ACTION(S): Repair the door immediately so that it is self-closing and latching. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.34 Pool design. (4) All pool areas shall be enclosed and have self-closing and latching gates or doors that are lockable.

[B] ATCP 76.11(2)(b) - SKIMMER BASKET OR WEIR MISSING

OBSERVATION: Three skimmers with stuck weirs.

CORRECTIVE ACTION(S): Replace or change style of weir. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.11 Recirculation system. (2) (b) Skimmers, skimmer weirs, and overflow gutters and drains shall be maintained so that they are clean and shall be repaired or replaced as needed. Skimmer covers shall be securely seated on deck.

[B] ATCP 76.27(1) - BLANKETS MISSING

OBSERVATION: 2 durable blankets are not available in the pool area.
Missing first aid kit.

CORRECTIVE ACTION(S): Provide 2 durable blankets in the pool area.

Provide supplied first aid kit. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.27 First aid supplies. (1) A first aid kit of a sort approved by the department and 2 durable blankets in good condition shall be available at each pool area. The first aid kit shall contain all of the following items:

1. Gauze pads - 4" x 4", 2. Gauze pads - 8" x 10", 3. Adhesive bandages, 4. Triangular bandages, 5. Scissors, 6. Gauze roller bandage, 7. Tweezers, 8. Adhesive tape, 9. Eye wash, 10. Elastic bandage, 11. Disposable surgical gloves, 12. Resuscitation pocket face mask, 13. Instant cold packs.

[B] ATCP 76.29(1)(b) - RULES MISSING - GENERAL

OBSERVATION: The following rules are missing from the posting: [rules].

CORRECTIVE ACTION(S): Provide a sign in compliance with ATCP 76.29(1)(b). Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.29 Posting pool and water attraction rules. (1) GENERAL. (b) A legible sign showing pool use rules shall be posted in a conspicuous place or places in the pool area. The sign shall include at least all of the rules in this paragraph in letters at least one inch high. Pool rules in connection with water attractions, therapy pools or other specialized pools defined in s. SPS 390 or this chapter may not be eliminated or modified without approval by the department.

1. Do not enter the pool if you have a communicable disease or an open cut.
2. Do not bring food, drink, gum or tobacco into the pool.
3. Shower before entering the pool and after use of toilet facilities.
4. Do not run or engage in rough play in the pool area.
5. Do not bring animals into the pool area.
6. Diaper changing on the pool deck is prohibited.
7. Glass and shatterable items are prohibited in the pool area.

[B] ATCP 76.26(2) - TELEPHONE NOT IN ENCLOSURE

OBSERVATION: The emergency telephone is not in the enclosure.

CORRECTIVE ACTION(S): Provide a functional emergency telephone in the enclosure. Correct By: 25-Jul-2016

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.03 (2).

[C] ATCP 76.26(2) - EMERGENCY CONTACT PHONE NUMBERS NOT POSTED

OBSERVATION: The emergency numbers are not posted near the designated emergency phone.

CORRECTIVE ACTION(S): Post the emergency numbers near the designated emergency phone. Correct By:

25-Jul-2016

CODE CITATION: ATCP 76.26 Rescue equipment. (2) TELEPHONE. For outdoor pools, a working telephone shall be available in the pool area. For indoor pools, a working telephone shall be available within the enclosed area around a pool. A current list of emergency numbers and the facility's location shall be attached to or posted near the telephone. Cellular or cordless phones may not be used to comply with this subsection.

Note: A request for an alternative location for a telephone or another system of communication that provides access to emergency service during hours of pool operation may be made under s. ATCP 76.02 (2).

Comments

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

Beth Stiner

Doug Schaefer
(608) 785-9679