



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name HAMPTON INN	Facility Type Additional Indoor Pool
Facility ID # BSAW-86YH3W	Facility Telephone # 608 779-5000
Facility Address 308 HAMPTON COURT ONALASKA , WI 54650	
Licensee Name OAB ONALASKA HOTEL LLC	Licensee Address 308 HAMPTON CT ONALASKA , WI 54650

Pool Parameters	
Free Available Chlorine/Bromine	16.5
Combined Chlorine	
pH	7.4
Alkalinity	
Cyanuric Acid	
Temperature	103
Flowmeter Reading(s)	80
Pressure Gauges Reading(s)	

Inspection Information		
Inspection Type	Inspection Date	Total Time Spent
Routine	02/08/2016	

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
Total # 0

Comments
VGBA - sidewall inlets were replaced last year. Main drain is due in 2020.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

Doug Schaefer
(608) 785-9679



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name HAMPTON INN	Facility Type Indoor Pool
Facility ID # BSAW-86YH3C	Facility Telephone # 608 779-5000
Facility Address 308 HAMPTON COURT ONALASKA , WI 54650	
Licensee Name OAB ONALASKA HOTEL LLC	Licensee Address 308 HAMPTON CT ONALASKA , WI 54650

Pool Parameters	
Free Available Chlorine/Bromine Combined Chlorine	11
pH	7.4
Alkalinity	
Cyanuric Acid	
Temperature	81
Flowmeter Reading(s)	100
Pressure Gauges Reading(s)	

Inspection Information		
Inspection Type Routine	Inspection Date 02/08/2016	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
Total # 0

Comments
VGBA-sidewall inlets were changed last year and the the main drain is due in 2010.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Sanitarian

Doug Schaefer
(608) 785-9679