



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name QUALITY INN	Facility Type Indoor Pool
Facility ID # ASTS-A97J2T	Facility Telephone # 608
Facility Address 1830 ROSE ST LA CROSSE, WI 54603	
Licensee Name ROSE HOTELS LLC	Licensee Address 2510 PLAZA CT WAUKESHA, WI 53186

Pool Parameters	
Free Available Chlorine/Bromine	3.2
Combined Chlorine	0
pH	7.2
Alkalinity	180
Cyanuric Acid	
Temperature	88
Flowmeter Reading(s)	40
Pressure Gauges Reading(s)	30

Inspection Information		
Inspection Type Routine	Inspection Date February 7, 2017	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 1</p> <p>Observed Violations - 04 - Skimmers, gutters, drains, water inlets - number, clean, good repair, installed, operated OBSERVATION: The weir door is missing on filter nearest whirlpool. CORRECTIVE ACTION(S): Replace the missing equipment. Correct By: 28-Feb-2017 CODE CITATION: ATCP 76.11 Recirculation system. (2) (b) Skimmers, skimmer weirs, and overflow gutters and drains shall be maintained so that they are clean and shall be repaired or replaced as needed. Skimmer covers shall be securely seated on deck.</p>

Comments

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Sanitarian



Nicole Frankfourth
(608) 785-9731



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name QUALITY INN	Facility Type Additional Indoor Pool
Facility ID # ASTS-A97J34	Facility Telephone # 608
Facility Address 1830 ROSE ST LA CROSSE, WI 54603	
Licensee Name ROSE HOTELS LLC	Licensee Address 2510 PLAZA CT WAUKESHA, WI 53186

Pool Parameters	
Free Available Chlorine/Bromine	5.2
Combined Chlorine	0.4
pH	7.6
Alkalinity	190
Cyanuric Acid	
Temperature	104
Flowmeter Reading(s)	60
Pressure Gauges Reading(s)	27

Inspection Information		
Inspection Type Routine	Inspection Date February 7, 2017	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
<p>Total # 1</p> <p>Observed Violations - 16 - pH alkalinity within limits or balanced, Cyanuric acid - within limits, Superoxidation - done as needed. OBSERVATION: The total alkalinity is 190. CORRECTIVE ACTION(S): Maintain the total alkalinity between 60 and 180 ppm. Correct By: 07-Feb-2017 CODE CITATION: ATCP 76.14 Disinfectant feeding and residuals. (4) CHEMICAL CONCENTRATIONS AND RESIDUALS. (d) Alkalinity. The total alkalinity of pool water shall be maintained between 60 and 180 ppm as calcium carbonate unless it can be shown that another level of total alkalinity produces chemically balanced water based on calculations approved by the department.</p>

Comments

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



Sanitarian



Nicole Frankfourth
(608) 785-9731