



Recreational Water Establishment Inspection Report

Establishment Information	
Facility Name WATERFORD VALLEY POOL	Facility Type Outdoor Pool
Facility ID # HSAT-7QXB3X	Facility Telephone # 608
Facility Address N1132 BLOOMER MILL RD LA CROSSE , WI 54601	
Licensee Name WATERFORD VALLEY	Licensee Address N1132 BLOOMERMILL RD LA CROSSE , WI 54601

Pool Parameters	
Free Available Chlorine/Bromine	3.5
Combined Chlorine	0
pH	7.4
Alkalinity	80
Cyanuric Acid	<30
Temperature	86
Flowmeter Reading(s)	115
Pressure Gauges Reading(s)	10, 11

Inspection Information		
Inspection Type Routine	Inspection Date 06/14/2016	Total Time Spent

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations
Total # 0

Comments
<ol style="list-style-type: none"> 1. Reviewed pool logs 2. Small cracks in concrete deck. In progress to be fixed.

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge

Ty Cooper

Sanitarian

Nicole Frankfourth
(608) 785-9731